



Central Valley Health District
Environmental Health Department
Aquatic Inspection Form

Aquatic Facility Name: Gaulker Family Wellness Center		Aquatic Facility License Number: AF30	
Address: 733 8th Ave SW	City: Valley City	State: ND	Zip: 58072
Phone:		Date: 01.16.2026	
Purpose for visit: complaint		Time In: 9:00am	Time Out: 10:00am
Pool/Spa Area			In/Out
01 Enclosure: fencing, walls, gates, and doors in good repair			N/A <input type="checkbox"/>
02 Self-closing / self-latching gates or doors operational			N/A <input type="checkbox"/>
03 Protected overhead electrical wires/GFCI electrical receptacles			N/A <input type="checkbox"/>
04 Grab rails, ladders secured; shell, deck in good repair			N/A <input type="checkbox"/>
05 Float/safety line clearly present			N/A <input type="checkbox"/>
06 "Depth" and "no diving" markers; stair stripes, in good repair and visible			N/A <input type="checkbox"/>
07 Skimmers: Weirs and basket installed; clean and operating; covers in good repair			N/A <input type="checkbox"/>
08 Recirculation inlets functional			N/A <input type="checkbox"/>
09 Main drain grate secured in place and in good repair			In <input type="checkbox"/>
10 Water is clear, main drain visible			In <input type="checkbox"/>
11 Floatation Tank: Interior surfaces cleaned to prevent build-up of slime and biofilm layers			N/A <input type="checkbox"/>
12 Starting blocks removed, covered, or access blocked			N/A <input type="checkbox"/>
13 Pool deck free from obstructions; emergency exit marked			In <input type="checkbox"/>
14 Emergency phone or other communication device available and well-marked			N/A <input type="checkbox"/>
15 First Aid Kit available			N/A <input type="checkbox"/>
16 Appropriate safety equipment present and in good repair			N/A <input type="checkbox"/>
17 Adequate supervisions of the aquatic facility			In <input type="checkbox"/>
18 Signs: rules/chemicals/spa legible and in good repair			N/A <input type="checkbox"/>
19 Water temperature ≤ 104°F (40°C)			In <input type="checkbox"/>
Water Chemicals			
20 Approved NSF/ANSI Standard 50 DPD test kit			N/A <input type="checkbox"/>
21 Proper disinfectant level			In <input type="checkbox"/>
22 pH between 7.2 and 7.8			In <input type="checkbox"/>
23 Combined chlorines < 0.4ppm			N/A <input type="checkbox"/>
24 Cyanuric acid ≤ 90 ppm			N/A <input type="checkbox"/>
Equipment / Chemical Room			
25 Automated feeders/controllers operable			N/A <input type="checkbox"/>
26 Piping and valves identified and marked			N/A <input type="checkbox"/>
27 Flow meter present and operating			N/A <input type="checkbox"/>
28 Recirculation pump: approved, good repair, operating			N/A <input type="checkbox"/>
29 Filter: approved, good repair, operating			N/A <input type="checkbox"/>
30 Pump strainer: baskets in good condition, not clogged			N/A <input type="checkbox"/>
31 Filter gauges operable: filter inlet and outlet, strainer			N/A <input type="checkbox"/>
32 Proper functioning UV system; ozone system			N/A <input type="checkbox"/>
33 Floatation Tank: Ozone or UV system in proper working order and meets volumetric turnover requirements			N/A <input type="checkbox"/>
34 Chemicals: labeled, stored safely, secured			N/A <input type="checkbox"/>
35 Appropriate Personal Protective Equipment (PPE) Available			N/A <input type="checkbox"/>
Hygiene Facilities			
36 Diaper Changing station present; sink, adjacent trash can			N/A <input type="checkbox"/>
37 Used equipment separated from cleaned equipment			N/A <input type="checkbox"/>
38 Toilets: clean, good repair, bathroom appropriately stocked			N/A <input type="checkbox"/>
39 Rinse/cleansing showers: good repair accessible			N/A <input type="checkbox"/>
Records Room			
40 Lifeguard and / or Operator training certification available onsite			N/A <input type="checkbox"/>
41 Inspection report conspicuously posted			N/A <input type="checkbox"/>
42 Operator inspection daily items: checklist used daily; evidence of appropriate steps promptly taken			N/A <input type="checkbox"/>
43 Chemical records: filled out daily, evidence of appropriate steps promptly taken			N/A <input type="checkbox"/>
44 Emergency Action Plan available on site			N/A <input type="checkbox"/>
General			
45 Substantial unauthorized alterations/equipment replacement			
46 Other			



Item #	Description of Violation	Corrective Actions	Correct By Date

Inspection Published Comment:

CVHD reviewed complaint with facility (attached pages 3 and 4). Facility unaware of complaint. Facility stated testing ranges are recorded by staff and when outside of range those results are recorded and management is informed so further action can be taken.

Facility is working with Johnson Controls to address HVAC issues, expected time line for repair is by February 2026.

paint peeling -facility will address once HVAC is in proper order

loose tile near meeting room entrance - facility will address once HVAC is in proper order, in the interim facility inform patrons.

sound board separating -facility will address once HVAC is in proper order

mold on outlet behind lane divider storage -facility will disinfect. Facility will continue to address mold as needed.

Facility stated fecal incidents are handled in accordance with CVHD Rule #2. CVHD informed facility of concern regarding non compliance with Red Cross, which is outside of CVHD Rule #2 authority.

Facility unaware of operational concerns during week of Dec. 7th, facility will look into.

Facility works with Associated Pools on the following:

automated feeder, maintenance done in Dec. 2025 facility has maintenance contact with Associated

Associated is aware of UV is working on

Facility plans to have Associated provide technical assistance on next media replacement

Facility stated unaware outdoor pool electrical concerns will follow up.

Facility stated cyanuric acid would be tested by aquatic manager.

In = In compliance Out = Not in compliance N/A = Not Applicable N/O = Not Observed COS= Corrected On Site R= Repeat

Follow up: Yes Follow up date: during subsequent inspections

Facility Representative: **Hilary Flatt**

Facility Signature: _____

Inspector: **Marcie Bata**

Inspector Signature: 

Date Filed: 01.14.2026

Regarding Facility: Gaulker Family Wellness Center and VCPR Outdoor Pool

Concern(s):

Both Facilities

Testing

- Staff is instructed to log results in operational range – inform management of results outside of range but log a number that is in range
- No closure or chemicals added/adjusted when report outside of range are made

Staff training – no chlorine in pool while staff completed Red Cross training

Issues are brought up but not addressed

Gaulker Family Wellness Center

HVAC DHU

-Issue since June 2025 -guard were originally resetting HVAC, however have now been informed not to reset ~ November 2025 . At that time partially disabled HVAC, the following week completely disabled, resulting in water running down wall.

- Tiles have started to separate
- Paint peeling behind chair on north wall
- Outlets on east wall not working
- Soundboards started HVACto separate on north wall

Mold

- Starting blocks, patrons took photos January 2026
- Around fire extinguisher box
- Lifeguard tubes have mold, now stored in office
- On ropes

Staff lie on cleaning sheets

Disinfectant cleaning spray bottle not working for months requests have been made to replace

Fecal incident

- fecal material disposed of in trash not in accordance with Red Cross training.

- Fecal material sat overnight facility removed following morning and reopened at 4pm.

Pool filters

- week of Dec 7 2025 filters plugged up no circulation chlorine near zero unable to see bottom of pool
- swimmers allowed, parents of lessons/team voiced concerns

Facility does not change filter media as required

Automated feeders not working on hot tub or pool

UV strainer not working

VCPR Outdoor

Cyanuric Acid used at outdoor not tested for

Chemical box/circulation pump tied to one breaker box, Hawkins informed facility need to change electrical to prevent chemical release

Pressure built up in pipes and blew out unsure damage in concrete

Drain covers need replacing