

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer*		pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
			Free	Total									
0	11-26	3:59	1.24	1.24	7.5		79		80.6°	492	50	741	R6
0	11-26	6:50	1.53	1.53	7.6		71		86°	474	50	732	DR
0	11-28	10:55	1.46	1.46	7.7		62		86°	494	50	749	DR
0	11-28	7:00	1.32	1.32	7.8		66		86°	498	50	737	R6
0	11-28	9:00	1.42	1.42	7.7		60		86°	501	50	750	DS
0	11-29	2:00	1.35	1.35	7.7		64		86°	490	50	749	DR
0	11-29	5:54	1.25	1.25	7.6		60		86°	489	50	748	R6
0	11-30	12:00	1.37	1.37	7.4		62		86°	510	50	730	DS
0	11-30	3:58	1.50	1.50	7.5		61		86°	491	50	721	CR
0	12-1	10:53	1.51	1.51	7.6		65		86°	460	50	694	AR
0	12-1	3:50	1.62	1.62	7.5		63		86°	451	50	704	DR
0	12-1	6:55	1.96	1.96	7.5		80		86°	461	50	719	GB

Required Ranges:	Free Chlorine	Bromine	pH	Cyanuric Acid	Recommended Ranges:	Alkalinity	Calcium Hardness
Aquatic Venue	No CVA 1.0 - 10.0 ppm With CVA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer**		pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of repairs, etc.
			Free	Total									
0	12/2	5:55	1.84	1.84	7.6		74		86°	458	50	710	W
0	12/2	10:33	1.26	1.26	7.7		60		86°	467	50	710	RG
0	12/2	3:54	1.39	1.39	7.3		60		86°	474	50	761	RG
0	12/2	6:52	1.58	1.58	7.2		66		86°	478	50	760	ED
0	12/3	8:00	1.74	1.74	7.7		62		86°	498	50	762	PS
0	12/3	10:50	1.67	1.67	7.5		61		86°	475	50	764	AR
0	12/3	3:50	1.03	1.03	7.2		62		86°	488	50	760	VS
0	12/3	6:54	1.40	1.40	7.8		99		86°	486	50	758	GB
0	12/4	5:54	1.61	1.61	7.3		60		86°	480	50	764	AR
0	12/4	10:35	1.57	1.57	7.2		60		86°	484	50	753	RG
0	12/4	3:53	1.39	1.39	7.3		60		86°	475	50	746	RG
0	12/4	6:54	1.65	1.65	7.2		60		86°	453	50	743	GB

Required Ranges:	Free Chlorine		Bromine	pH	Cyanuric Acid	Recommended Ranges:	
	Aquatic Venue	Spa				Aquatic Venue	Spa
	No CYA 1.0 - 10.0 ppm	3.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	60 - 180 ppm	60 - 180 ppm
	With CYA 2.0 - 10.0 ppm	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	60 - 180 ppm	100 - 800 ppm

* pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 ** If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer**		pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
			Free	Total									
0	12/5	8:20	1.31	1.31	7.6		66		86°	465	50	710	AR
0	12/5	10:50	1.27	1.27	7.4		67		86°	502	50	705	RS
0	12-5	3:53	1.29	1.29	7.8		75		86	461	50	696	RG
0	12/6	9:00	1.13	1.13	7.5		67		86	454	50	724	DR
0	12-6	5:47	1.86	1.86	7.6		84		86	187	50	607	RG
0	12/7	12:07	1.65	1.65	7.8		144		86	113	50	685	GP
0	12/2	3:14	1.52	1.52	7.9		132		86	502	50	524	RS
0	12/8	8:20	1.12	1.12	7.7		89		86°	218	50	494	RS
0	12/8	10:55	1.17	1.17	7.6		81		86°	215	50	485	AR
0	12/8	3:50	1.31	1.31	7.6		70		86°	232	50	477	AR
0	12/8	6:45	1.67	1.67	7.6		74		86°	457	50	471	RS
0	12/1	6:00	1.70	1.70	7.3		75		86°	50	50	423	DF

Required Ranges:	Free Chlorine		Bromine	pH	Cyanuric Acid	Recommended Ranges:		
	Aquatic Venue	Spa				Alkalinity	Calcium Hardness	
	No CYA 1.0 - 10.0 ppm	3.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
	With CYA 2.0 - 10.0 ppm	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer** Free Total	CC	pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
0	12-11	12:51	4.34	0	7.8		88		88°	658	90	429	RC
0	12/11	6:50	4.18	0	7.8		96		86°	650	90	481	AR
0	12/11	8:30	4.2	0	7.7		103		N/A	652	90	434	HP
0	12/12	10:55	2.60	0	7.4		79		86°	647	90	633	AR
0	12-12	3:57	2.86	0	7.6		84		86°	650	90	650	RC
0	12/13	9:50	2.62	0	7.7		90		86°	661	90	681	DS
0	12/13	1:50	1.90	0	7.7		103		86°	673	90	684	AR
0	12-14	1:53	1.63	0	7.5		86		86°	675	90	698	RC
0	12/14	4:00	1.82	0	7.6		79		86°	685	90	675	DS
0	12-15	10:50	1.10	0	7.5		79		86°	653	90	670	CA
0	12/15	3:50	1.87	0	7.7		80		86°	657	90	666	AR
0	12/15	7:00	1.79	0	7.4		84		86°	650	90	664	DS

Required Ranges:	Free Chlorine	Bromine	pH	Cyanuric Acid	Recommended Ranges:	Alkalinity	Calcium Hardness
Aquatic Venue	No CYA 1.0 - 10.0 ppm With CYA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer*		pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
			Free	Total									
0	12/16	6:00	1.63	1.63	7.5		78		86	648	90	662	DT
0	12/16	10:55	1.60	1.60	7.5		85		86	646	90	633	RC
0	12/16	8:57	1.20	1.20	7.3		83		86	621	98	636	RC
0	12/16	7:00	1.88	1.88	7.5		72		86	634	90	615	DT
0	12/17	8:16	1.74	1.75	7.4		74		86	620	90	606	PS
0	12/17	10:14	1.73	1.73	7.4		72		86	632	90	606	PS
0	12/17	12:03	0.74	0.75	6.8		75		86	649	90	605	PFH
0	12/17	3:14	1.11	1.11	8.9		73		85	650	90	610	AD
0	12/17	6:56	1.13	1.13	6.9		72		86	636	90	625	KS
0	12/17	6:00	1.17	1.17	7.2		70		86	637	90	600	PS
0	12/18	10:52	3.08	3.08	7.7		89		86	656	90	669	RC
0	12/18	3:51	2.86	2.86	7.8		88		86	0	90	676	RC

Required Ranges:	Free Chlorine	Bromine	pH	Cyanuric Acid	Recommended Ranges:	Alkalinity	Calcium Hardness
Aquatic Venue	No CYA 1.0 - 10.0 ppm With CYA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons) : _____

Type: _____

Surface Area (sq ft) : _____

Open/Closed O/C	Date	Time	Sanitizer* Free Total	CC	pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
0	11/18	6:55	2.38	2.35	7.7		96		86	665	90	615	CA
0	11/19	5:25	2.57	2.59	7.8		92		86	630	90	614	AR
0	12/1	10:50	2.37	2.37	7.8		98		86	650	90	708	AR
0	12/1	3:58	2.49	2.49	7.7		98		86	649	90	710	AD
0	12/1	8:36	2.40	2.50	7.8		91		86	646	90	710	AD
0	12/1	1:50	2.73	2.73	7.7		98		86	654	90	711	AD
0	12/2	5:50	2.50	2.50	7.8		100		86	650	90	724	CS
0	12/2	12:06	2.81	2.81	7.8		89		86	654	90	736	AD
0	12/2	4:00	2.36	2.36	7.2		93		86	680	90	751	CA
0	12/2	8:30	3.50	3.00	7.3		91		86	649	90	704	AD
C	12/2	10:50	2.01	2.01	7.4		104		86	636	90	702	AD
0	12/22	5:55	2.04	2.04	7.5		99		86	640	90	703	LM

Required Ranges:	Free Chlorine	Bromine	pH	Cyanuric Acid	Recommended Ranges:	Alkalinity	Calcium Hardness
Aquatic Venue	No CYA 1.0 - 10.0 ppm With CYA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

* pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 ** If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: Gaukler Pool

Volume (gallons): _____

Type: _____

Surface Area (sq ft): _____

Open/Closed O/C	Date	Time	Sanitizer**		CC	pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
0	12/22	6:54	2.52	2.02	0	7.5		96		86°	636	90	690	EO
0	12/23	5:58	2.35	2.35	0	7.5		95		86°	632	90	678	GF
0	12/23	10:55	2.72	2.72	0	7.5		83		86	621	90	658	CF
0	12/23	3:52	2.22	2.33	0	7.7		82		86	641	90	650	RF
0	12/23	6:45	1.56	1.56	0	7.7		85		86	647	90	645	CF
0	12/24	10:50	1.74	1.74	0	7.6		80		86	652	90	655	HFZ
	12/24													Closed for Xmas
0	12/24	10:52	2.08	2.08	0	7.6		79		86°	645	90	731	GF
0	12/27	9:08	2.11	2.11	0	7.7		88		86	690	90	730	AD
0	12/27	2:00	2.44	2.44	0	7.6		79		86	694	90	734	AD
0	12/28	1:00	2.59	2.59	0	7.5		78		86	689	90	729	AD
0	12/28	12:00	3.00	3.00	0	7.4		79		86	692	90	730	AD

Required Ranges:	Free Chlorine		Bromine	pH	Cyanuric Acid	Recommended Ranges:	
	Aquatic Venue	No CYA 1.0 - 10.0 ppm With CYA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	Alkalinity
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	150 - 1,000 ppm
						60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.

Aquatic Venue Log

Facility Name: GFWC POOL

Volume (gallons) : _____

Type: _____

Surface Area (sq ft) : _____

Open/Closed O/C	Date	Time	Sanitizer** Free Total	CC	pH*	Cyanuric Acid	Alkalinity	Calcium Hardness	Water Temperature	Flow Rate	Filter Pressure	ORP- HRR	Comments: water added, quantity/type of chemical manually added, backwash, repairs, etc.
0	12/29	10:50	1.10	0	7.6		78		86°	682	90	658	AA
0	12/29	11:00	1.19	0	7.7		74		86°	673	90	660	AD
0	12/29	7:00	1.39	0	7.6		78		86°	679	90	666	AB
0	12/30	5:41	1.35	0	7.5		70		86°	642	90	627	G7
0	12/30	10:50	1.90	6	7.8		79		86°	633	90	597	BA
0	12/30	3:49	1.19	0	7.7		80		86°	629	90	557	RC
0	12/30	6:55	1.43	0	7.8		77		86°	652	90	531	CA
0	12/31	10:51	1.52	0	7.4		83		86°	617	90	450	G7F
0	12/31	3:45	3.55	0	7.6		86		86°	637	90	513	KW
0	1/1	10:35	4.51	0	7.8		98		86°	652	90	710	AR
0	1/1	3:50	4.65	0	7.8		78		86°	658	90	817	AR
0	1/1	6:50	9.98	0	7.8		88		86°	647	90	829	KS

Required Ranges:	Free Chlorine	Bromine	pH	Cyanuric Acid	Recommended Ranges:	Alkalinity	Calcium Hardness
Aquatic Venue	No CYA 1.0 - 10.0 ppm With CYA 2.0 - 10.0 ppm	3.0 - 8.0 ppm	7.2 - 7.8	90 ppm maximum	Aquatic Venue	60 - 180 ppm	150 - 1,000 ppm
Spa	3.0 - 10.0 ppm	4.0 - 8.0 ppm	7.2 - 7.8	Not allowed	Spa	60 - 180 ppm	100 - 800 ppm

*pH and sanitizer levels must be recorded at minimum prior to start up and every 4 hours.
 **If pH and sanitizer levels are outside of required range aquatic venue shall be closed until levels meet required range.
 All chemicals manually added and maintenance done shall also be recorded. All records must be kept for at least three years.